

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: TOWN PUMP INC THREE FORKS
10800 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-08721
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	41	4/14/1974	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4543			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	41	4/14/1974	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4681			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	41	4/14/1974	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4544			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	35	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4545			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: TOWN PUMP INC THREE FORKS
10800 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-08721
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	35	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4546			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	35	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2450			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	27	1/1/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4886			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	27	1/1/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2452			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
12	27	1/1/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4882			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: TOWN PUMP INC THREE FORKS
10800 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER

Sys Fac ID: 16-08721
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
13	11	2/2/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4931			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: WHEAT MONTANA FARMS INC
10778 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER

Sys Fac ID: 56-14009
Last Inspected On: 3/28/2013
Operating Permit Renewal Date: 7/7/2016

Contact: Dean Folkvord, (406) 285-3614

Owners/Operators: Wheat Montana Bakery Inc, Owner (406)-285-3614 10778 US HIGHWAY 287
THREE FORKS MT 59752-9518
Russell Barnett, UST Class A Operator
Peter Carlson, UST Class A Operator
Russell Barnett, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4384		6/13/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
2	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4385		6/13/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
3	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4386		6/13/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: TOWN PUMP INC TOWNSEND
206 N FRONT ST
TOWNSEND, MT 59644 BROADWATER

Sys Fac ID: 04-03456

Last Inspected On: 7/18/2015

Operating Permit Renewal Date: 10/27/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump of Townsend Inc, Owner (406)-497-6700 600 SOUTH MAIN ST
BUTTE MT 59701-2534
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	20	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2386			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	20	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2387			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
10,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	20	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2388			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
12,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: TOWN PUMP INC TOWNSEND
206 N FRONT ST
TOWNSEND, MT 59644 BROADWATER
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 04-03456
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	20	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2389			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
12,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root		
11	02	7/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5428		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Continuous Interstitial Monitor, Stat. Inventory Reconciliation	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes
12	02	7/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5429		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Continuous Interstitial Monitor, Stat. Inventory Reconciliation	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: ROCKY MOUNTAIN SUPPLY INC TOWNSEND
310 S FRONT ST
TOWNSEND, MT 59644 BROADWATER

Sys Fac ID: 04-07862

Last Inspected On: 2/28/2013

Operating Permit Renewal Date: 4/15/2016

Contact: Jason Rorabaug, (406) 388-4008

Owners/Operators: Rocky Mountain Supply Inc, Owner

(406)-388-4008

JASON RORABAUGH PETROLEUM MGR
PO BOX 129
BELGRADE MT 59714-3035

Jason Rorabaugh, UST Class A Operator

Carla Ahern, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4298			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/28/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		1/19/2010			
8	20	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4299			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/28/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		1/19/2010			
9	20	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4300			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/28/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/19/2010			
10	20	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4301			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/28/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/19/2010			

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: ROCKY MOUNTAIN SUPPLY INC TOWNSEND
 310 S FRONT ST
 TOWNSEND, MT 59644 BROADWATER
Contact: Jason Rorabaug, (406) 388-4008

Sys Fac ID: 04-07862
Last Inspected On: 2/28/2013
Operating Permit Renewal Date: 4/15/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	03	8/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5382		11/7/2012	Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000					Yes
12	03	8/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	
5383		11/7/2012	Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000					Yes

Facility Summary in BROADWATER County in the City of WINSTON

Location: WINSTON STORE
 6473 US HIGHWAY 287
 WINSTON, MT 59647 BROADWATER
Contact: Allen L. Brewer, (406) 227-5597

Sys Fac ID: 04-00280
Last Inspected On: 9/29/2014
Operating Permit Renewal Date:

Owners/Operators: Allen Brewer, Owner (406)-227-5597 1134 8TH AVE
 HELENA MT 59601
 Allen L Brewer, UST Class A Operator
 Allen L Brewer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	22	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3152			None	None	Yes
Temporarily Out of Use		9/1/2003	Not Required	Safe Suction	Galvanic
Gasoline		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,000					
4	22	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3153			None	None	Yes
Temporarily Out of Use		9/1/2003	Not Required	Safe Suction	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,000					